



Legend:

- 1 Level silo discharge
- 2 Metering screw
- 3 Stoker in RSE
- 4 Boiler base with ash pan
- 5 3 draft special wood combustion boiler in a recumbant position
- 6 Dust removal system Multi-cyclone
- 7 Suction draft fan
- 8 Electrical control cabinet
- 9 Smokestack
- 10 Vent holes in the boiler house
- Access ladder

Design and construction proposal
for a smoke-free and fully automated
WOOD-CHIP HEATING SystemKURRI

Performance 500 - 2.000 kW out-put
Silo 300 - 800 m³

Scale: 1:50

K.R.Ing. Ernst KURRI
Fliebergasse 70
A-2700 WR.NEUSTADT
Tel. 0043/(0)2622/23865 / - Fax 15